



LEGEND

- +— CONDUCTORS CONNECTED
- |- CONDUCTORS NOT CONNECTED
- ← CONDUCTOR INDICATING LOAD DIRECTION
- CURRENT TRANSFORMER

Only qualified electrical personnel should install this equipment.

- Before performing installation or maintenance, disconnect all sources of electric power.
- Use appropriate personal protective equipment (PPE) and follow safe electrical work practices.

Find diagrams for more configurations at wattwatchers.com.au/support

- Installation Notes:**
- 1) Auditor is DIN-rail mounted and requires 35mm wide space.
 - 2) CET PMC-340B is DIN-rail mounted and requires 126mm wide space.
 - 3) Current transformer installation –
For grid monitoring, K is towards grid, arrow is towards load.
For solar monitoring, K is towards inverter, arrow is towards load.
 - 4) Current transformers must be suitably secured in position.
 - 5) All wiring shall be tidy and secured in accordance with the wiring rules in your jurisdiction.
 - 6) An existing or new protective device can be used depending on the regulations in your jurisdiction.
 - 7) Follow the rules in your jurisdiction for the use of RCD protection.
 - 8) For more information, refer to the quick start guide and wattwatchers.com.au/support

Place current transformer connected to Auditor A6M...	On cables connected to...
Terminals 1+ and 4+	A-Phase
Terminals 2+ and 5+	B-Phase
Terminals 3+ and 6+	C-Phase

Issue	Description	Drawn	Approved	Date
1	Final	JC	JC	08/19



COPYRIGHT 2019 BY WATTWATCHERS
ALL RIGHTS RESERVED. NO PART OF THE CONTENTS OF THIS DRAWING MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM BY PARTIES OTHER THAN THOSE EMPLOYED BY OR ENGAGED BY WATTWATCHERS AND ONLY IN DIRECT CONNECTION WITH THE PURPOSE FOR WHICH THIS DRAWING HAS BEEN PROVIDED WITHOUT THE WRITTEN PERMISSION OF WATTWATCHERS

Client Details

Drawn By: KS
Date: 08/19
Approved By: JC
Date: 08/19

Project Title: CONNECTION DIAGRAMS

Drawing Title: A6M+Dne AUDITOR MONITORING 3-PH GRID + SOLAR CET DIRECT-CONNECT MONITORING SOLAR

Project Code: 20180482
Status: FINAL
Revision: A
Drawing No.: WW018055
Scale: NTS