



ROOF SYSTEM ASSESSMENT REPORT DYNAMIC UPLIFT RESISTANCE PER CSA A123.21			
CLIENT:	SEAMAN CORPORATION	TEST DATE:	2019-11-05
DOCUMENT NO.	SMN-MARS-4	PUBLICATION DATE:	2020-02-04
TEST PANEL NO.	SMN-D7	REVISION NO.	1
SYSTEM TYPE:	C-2	REEVALUATION DATE:	2023-01-10

MECHANICALLY ATTACHED ROOFING SYSTEM (MARS) SUMMARY

PERFORMANCE⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (with SF of 1.5)
	179 psf (8.57 kPa)	119 psf (5.70 kPa)

COMPONENT	ALLOWABLE PRODUCTS	BY
MEMBRANE⇒	FiberTite (nominal 36 mil), FiberTite-SM (nominal 45 or 60 mil), FiberTite-XT (nominal 50 or 60-mil) or FiberTite XTreme (nominal 60-mil)	Seaman Corporation
ATTACHMENT:	induction welded to FTR-IW isoweld Plates using the isoweld Induction Bonding Tool and isoweld Magnets	
INSULATION, TOP LAYER⇒	Min. 1.5-inch FTR-VALUE A, FTR-VALUE or FTR-VALUE H Min. 1.5-inch ACfoam II Min. 1.5-inch ISOLEX A Min. 1.5-inch ENRGY 3 or Min. 1.5-inch H-Shield	Seaman Corporation Atlas Roofing Lexsuco 2010 Corp. Johns Manville Hunter Panels
ATTACHMENT:	24 parts per 4x8 ft board; 1.5 ft (along board width) x 1 ft (along board length) grid pattern	<p>6" 8" 6" 7 spaces @ 12" 6" 24 Fast. / bd.</p>
	FiberTite Magnum Fasteners with FTR-IW isoweld Plates	
INSULATION, BASE LAYER⇒	One or more layer(s), min. 1.5-inch thick base insulation or min. 1.0 pcf IZOLON by FRANSYL or other expanded polystyrene meeting ASTM C578, acceptable to the Authority Having Jurisdiction	various
ATTACHMENT:	loose-laid	

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CLIENT:	Seaman Corporation	PUBLICATION DATE:	2020-02-04
DOCUMENT NO.	SMN-MARS-4	REVISION NO.	1
TEST PANEL NO.	SMN-D7	REEVALUATION DATE:	2023-01-10



NEMO|etc.

Page 2 of 2

COMPONENT	ALLOWABLE PRODUCTS	BY
VAPOUR BARRIER⇒	6-mil polyethylene or	various
	VaporTite	Seaman Corporation
ATTACHMENT:	loose-laid or self-adhering	
THERMAL BARRIER⇒	(Optional) any type or thickness acceptable to the Authority Having Jurisdiction	various
ATTACHMENT:	loose-laid, adhered or mechanically attached	
DECK⇒	Minimum 22 ga. type B steel meeting ASTM A653, A792, A1008 or CSSBI 10M standards and having a yield strength of 275 MPa (40 ksi), or alternate steel deck providing the fastener withdrawal resistance noted below.	Various
FASTENER POINT-LOAD⇒	238 lbf (1059 N)	

END OF REPORT